



VAPPRO-SDT

SMOKE DETECTOR TESTER

FUNCTIONAL TEST FOR SMOKE DETECTOR OPERATIONS

NATO STOCK NUMBER
6850-32-080-0512



CONTENTS 400 ML



DESCRIPTION

Vapro SDT is fortified with Vapro VCI Inhibitor. It is an aerosol spray that provides a full functional test of both residential and commercial smoke detectors.

Now testing smoke detectors is easier and more efficient than ever. With Vapro SDT simply stand under the smokedetector and spray. The aerosol mist simulates actual smoke particles and triggers the alarm. If the alarm fails to sound, immediately inspect the detector for dead batteries, clogged vents, or electronic malfunctions.

Vapro SDT is not only offered to those professionals involved in fire prevention and safety, but to anyone interested in home and workplace fire prevention.

DIRECTIONS FOR USE

- Shake well before use.
- Spray for 5 seconds, repeat if necessary.
- If detector fails to respond within 1 minute, it may be faulty. Insert a replacement detector and test again.



PROPERTIES

Boiling Point
Propellant < -18°C

Color
Colorless

Specific Gravity
0.785±0.025

pH
7±0.5

Physical Form
Liquid

Vapour Pressure
33 mmHg@ 20°C

Magna

HEADQUARTERS, SINGAPORE

Magna International Pte Ltd
10H, Enterprise Road,
Singapore 629834.
Tel (65) 6788-1228
Fax (65) 6785-1497
Email info@magnachem.com.sg
Website
http://www.magnachem.com.sg

NORTH AMERICA

1450 Government Road West
Kirkland Lake, Ontario P2N 2E9
Canada
Tel 1.416 479 9151
Fax 1.888 317 1993
Email magna@vapro.com
Website: http://www.vapro.com



Copyright 2007. The details of our products are given completely free of undertaking. Since their application lies outside our control, we cannot accept any liability for the results. User shall determine the suitability of the product for its intended use, and user assumes all risk and liability whatsoever in connection therewith.



VAPPRO AEROSOL

V.C.I. CORROSION INHIBITOR